



## ZANGRILLI ENGINEERING

322 Oriskany Boulevard  
Whitesboro, New York 13492  
(315) 736-7011 Fax (315) 736-7013  
e-mail: zangeng@ntcnet.com

June 13, 2002

Catholic Cemeteries, Diocese of Syracuse  
2315 South Avenue  
Syracuse, New York 13207

Attention: Mark Lazaroski

Re: Holy Trinity Cemetery  
Whitestown, New York

Dear Mr. Lazaroski:

There are some problems with the Holy Trinity Cemetery Expansion Project that are impacting the Village of Yorkville. I visited the site on June 12, 2002 and observed two inadequate conditions. First, the sediment and erosion control measures being used are not adequate. Every time it rains silt and soil is being washed down the hill to the north west corner of your property and into the Village of Yorkville storm system. The silt and soil is plugging the catch basin and storm pipes. This problem is magnified with the heavy rains we have been experiencing recently. Second, the present grading is not as shown on the approved grading and drainage plan. The approved grading plan shows the storm water from all but approximately 41,132 square feet of land running into the new detention basin. The storm water from this 41,132 square feet of land is directed toward Douglas Avenue. The present grading has storm water generated from approximately 197,196 square feet of land running down the old Village of Yorkville right-of-way toward Douglas Avenue. During heavy rains, this storm water is running off of your property onto Village resident's property along Cross Street. This storm water is mixed with silts and soil. The silt and soil is being deposited on the Village of Yorkville resident's property.


1 of 2

Attachment A  
1/2

These problems must be corrected immediately. Proper sediment and erosion control devices must be installed to keep silt and soil from entering the Village of Yorkville's storm sewer system. The grading must be completed and improved to keep storm water from flowing onto the adjacent property along Cross Street.

Should you have any questions or comments concerning this matter, please contact me.

Very truly yours,



Albert A. Zangrill, PE

cc: Village of Yorkville,  
Michael Mahoney, Mayor

Village of Yorkville,  
Conrad Chaya, Highway Superintendent

Town of Whitestown,  
Karl Schrantz, Planning Board Chairman

Grever & Ward, Inc.  
David G. Ward

Robert Ross